

ITB # 201922 – Parks & City Yards Utilities Project

Questions & Answers

Updated 8/16/19

Q1. Where do you get a blasting permit?

A1. Fire Department located at 21 S. Kent.

Q2. Since there will be two contractors, how are rock quantities to be billed?

A2. Rock associated with utility installation will be billed under this contract.

Q3. Can bidders visit the construction locations?

A3. Yes, both are open to the public.

Q4. Can VDOT pre-qualification be subbed for company financials in the Contractor Qualification Data Sheet?

A4. Yes

Q5. On the plans for City Yard Utilities (sheet B8) there is a 3" meter vault called out with 3" Service line going into it. I referenced the detail on the City website and it calls out 4" DIP for all piping. Could you please advise what type of pipe and what size you would like to use for this project?

A5. The 3" meter shown on the plans will actually be a 4" meter vault and piping.

Q6. Also, can you confirm that the city will provide the meter and the strainer from the detail? Or just the meter?

A6. The City will provide the meter and the strainer. The contractor will provide the vault and piping.

Q7. In looking over this Contractor's Qualification Data Sheet for this project I see that it is merely a set of instructions. Is there an actual data sheet to be filled out? The Instructions to Bidders section says that it must be submitted with the bid. This was also stated at the pre-bid meeting. Are we to provide this on our own account or is there a form on which to provide this information?

A7. You may use additional sheets, but they must be attached to the form in the bid package.