

ITB #202008

OWRF FOG Receiving Upgrades

Question and Answer (Q&A) Bulletin Board

(This document will be updated periodically to share all relevant questions and answers.)

Q1: *Please provide a specification for the floor drains.*

A1: **Floor Drains Shall be Model 2230, or 2240 by J.R. Smith, or equal products by Zurn or Wade. This requirement will be added in forthcoming Addendum # 1**

Q2: *Please provide information as to where the hot water lines extend to, ref: drawing M103*

A2: **Hot water is supplied to the Envirocare Beast and to the hose reel. Drawings will be modified by forthcoming Addendum # 1**

Q3: *Can we get sizing on the overhead roll-up door?*

A3: **The door should be sized for an 8 ft. wide by 10 ft. high rough opening.**